



Product Service

Attestation of Conformity

No. N8A 107931 0012 Rev. 02

Holder of Certificate: YUHUAN SUNPRO POWER CO.,LTDQinggang Technological Ind.Zon,
317606 Yuhuan, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062011501-02**Date,** 2021-12-02

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 107931 0012 Rev. 02

Model(s): SPxxx-72M, xxx=370 to 410 in step of 5,
 SPxxx-60M, xxx=305 to 340 in step of 5,
 SPxxx-54M, xxx=280 to 310 in step of 5,
 SPxxx-48M, xxx=245 to 270 in step of 5,
 SPxxx-36M, xxx=185 to 205 in step of 5,
 SPxxx-144M, xxx=410 to 460 in step of 5,
 SPxxx-120M, xxx=340 to 385 in step of 5,
 SPxxx-144MG, xxx=380 to 415 in step of 5,
 SPxxx-120MG, xxx=315 to 345 in step of 5,
 SPxxx-144M10, xxx=520 to 550 in step of 5,
 SPxxx-132M10, xxx=480 to 505 in step of 5,
 SPxxx-120M10, xxx=435 to 460 in step of 5,
 SPxxx-108M10, xxx=390 to 415 in step of 5,
 SPxxx-120M12, xxx=580 to 605 in step of 5,
 SPxxx-110M12, xxx=530 to 555 in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

- EN IEC 61730-1:2018
- EN IEC 61730-1:2018/AC:2018-06
- EN IEC 61730-2:2018
- EN IEC 61730-2:2018/AC:2018-06